

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220586
Address: 908 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Wednesday, April 05, 2023

Corrective Action Required:

1	Miscellaneous Correction	- Provide building steel and ground rod grounding conductors, expose metallic water line grounding connection, provide direct metal to metal connection at disconnect bonding lug, provide #1/0 grounding conductors for all grounds and to disconnect
---	--------------------------	--

Comments: