

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221526

Address: 904 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081904 NW PRYOR RD, Unit:B, LEES SUMMIT, MO 64081904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, April 05, 2023

Corrective Action Required:

1	Misc	-Provide address at front and back doors -Provide emergency egress lighting -Ensure that all sight lighting is complete -Provide anchor bolts at all plate breaks -Complete electrical service installation (backordered main disconnect breaker) -Label fire wall -Protect all dwv 2" above and below plate lines -Complete corrections for LSFD
---	------	--

Comments: