

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20222664  
Address: 904 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Wednesday, April 05, 2023

Corrective Action Required:

1	Misc	<b>**OK TO STOCK ONLY-DO NOT OCCUPY</b> -Provide min air gap at all appliance drains -Provide ASSE 1022 backflow device for carbonated beverage dispenser -Install grab bars at restrooms to be code compliant -Relocate toilet in women's room to be within 16"-18" from side wall -Provide water resistant finish in restrooms at painted walls -Locate restroom mirrors to be max 40" to reflective surface -Paint all exterior gas lines -Remove trash and debris from rooftop -Secure rooftop electrical whips -Label separate gas services -Upload health department approval to portal -Update permit with new contractor information -Locate sewer tracer box at grade -Locate exterior clean outs at grade -Complete corrections for all other departments
---	------	--

Comments: