

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212708  
Address: 4705 NE FREEHOLD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Nick Scott	Failed	Thursday, April 06, 2023

Corrective Action Required:

1	Misc	4-6-2023 NS. Site visited the sidewalk and driveway passed city standards. But the water valve needs to have the tracer wire fix before I can pass this.
---	------	--

**Comments:**