

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216389
Address: 3230 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, April 06, 2023

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- pay fees- Provide splash pads- Final grading and sod- Seal exterior penetrations- Seal top of exterior light fixtures- Provide stairs for garage man door- Provide stairs for sliding door to patio- Missing outlet cover upstairs bathroom- Complete attic access- Support 3" DWV just inside basement door |
|---|------|---|

Comments: