

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215286

Address: 3643 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643643 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643643 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Thursday, April 06, 2023

Corrective Action Required:

1 Misc

EXTERIOR:

- Seal wall penetrations, above lights
- Provide tamper proof caps at AC valves
- Provide flashing above wall protrusion behind service equipment
- Install splash blocks
- Paint gas service piping

UNIT A:

- Remove tape from b-vent
- Install water heater P&T discharge pipe

UNIT B:

- Provide peep hole at front door
- Route water heater P&T discharge pipe to pan

UNIT C:-OK

Comments: