CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221526

Address: 904 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081904 NW PRYOR RD, Unit:B, LEES SUMMIT, MO

64081904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Inspection Robb Popp Failed Friday, April 07, 2023

Corrective Action Required:

1 Misc APPROVED FOR SERVICE-

WHEN 800AMP MAIN IS INSTALLED-LABELING NEEDS TO CHANGE.

Comments: