

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212440
Address: 1828 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Friday, April 07, 2023

Corrective Action Required:

1 Misc

- garage door must be self closing (it will not close shut and lock)
- outlet plate in utility room is not installed
- provide security screws at basement walkout, (2) 3" screws each hinge and strike plate
- water sprinkler permit is required for system already installed

Comments: