

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214745
Address: 130 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Devon Perry	Failed	Friday, April 07, 2023

Corrective Action Required:

1	Miscellaneous Correction	4-7-23 DP. When I came out to do a sidewalk inspection, my practice is to check cross slopes across the driveway as well. The entire driveway is 2.8% to 3.0% which is out of ADA compliance that maxes out at 2.0% cross slope. This Driveway approach needs to be replaced.
---	-----------------------------	---

Comments: