

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222664
Address: 904 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, April 10, 2023

Corrective Action Required:

1	Misc	**OK TO STOCK ONLY-DO NOT OCCUPY -Provide ASSE 1022 backflow device for carbonated beverage dispenser -Paint all exterior gas lines -Label separate gas services -Locate exterior clean outs at grade -Complete corrections for all other departments
---	------	---

Comments: