

File: PRCOM
20110360

John Borns

970 NW Blue Pkwy, Unit A

From: Todd Hinken [todd@camconstructioninc.com]
Sent: Monday, May 23, 2011 11:21 AM
To: John Borns
Cc: Mike Leardi; Russ Schuster
Subject: Fwd: SF Bldg O Corridor - City Coordination

Hello John

This is Todd at CAMM construction I received this E-mail from the architect Friday.
This should be our only remaining issue at summit fair I will contact Captain Dir. for a re inspection.

Thank you Todd

Begin forwarded message:

From: "Kevin Campbell" <kcampbell@souparch.com>
Date: May 20, 2011 12:47:04 AM CDT
To: "Todd Hinken" <todd@camconstructioninc.com>
Cc: "Mike Leardi" <mike@camconstructioninc.com>
Subject: SF Bldg O Corridor - City Coordination

Todd,

Per your request, I spoke with Mike Weisenborn today about the existing condition of the Bldg O roof line to the JC Penney building. He indicated that fire stopping is not required at the gap between the Bldg O roof edge angle and JC Penney exterior wall. A fire rated corridor is not required at this location, therefore, additional fire stopping at the roof line and gap above is not required. Please advise John Born of this conversation and the final determination by Mike Weisenborn.

Thank you,



Soup Studios | Kevin Campbell, AIA | kcampbell@souparch.com
6320 Brookside Plaza, Suite 511 | Kansas City, MO 64113 | 816.854.0700

Thank you,

Todd Hinken
Phone: 816-356-6900

Fax: 816-356-6901

Cell: 816-365-8894

todd@camconstructioninc.com

<http://www.camconstructioninc.com>

**Camm
Construction, Inc.**