

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214027  
Address: 4721 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Khanh Nguyen	Failed	Tuesday, April 11, 2023

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	MAINTAIN EROSION CONTROL AND STREET THROUGHOUT CONSTRUCTION 4-11-23 site visited erosion control has failed. Storm gutter full of mud. Will need to be cleaned out. Street full of mud. Sidewalks are full of mud. Need to be cleaned ASAP. Silt fence needs to be replaced or fixed on both sides of the house. Please call me when you have a crew on there way to fix this. Nick Scott 816-977-5652
---	----------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**