

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216223
Address: 106 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, April 11, 2023

Corrective Action Required:

1 Misc

- final grade and sod
- splash blacks and sump pump discharge to extend 36" from foundation
- raise water meter well lid to grade (ensure 14"-18" from meter to well lid)
- all outlets in master closet/laundry to be GFCI protected
- security screws at garage side door

Comments: