

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20223255  
Address: 2781 SW 12TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Devon Perry	Partial	Tuesday, April 11, 2023

Informational:  
1 Misc 4-11-23 DP. DW is formed, aggregate is compacted, told to maintain ADA cross slopes throughout driveway and also expansion/joint at header, curb, and sidewalks. Approved to pour

**Comments:**