

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223894
Address: 1046 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Tuesday, April 11, 2023

Partial Correction:

1	Misc	<ul style="list-style-type: none">- Complete plumbing to second floor tub above single garage bay and five block- Nail SE exterior corner to code- Solid block and nail off sheeting at breaks, front entry wall- Missing stud at owner suite/ gathering- Support rafter and end of top plate and tie into return wall above landing of stairs by entry- Address header joist for plumbing near electrical panel nail to code or use hangers
---	------	---

Comments: