

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221806
Address: 3208 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ryan Heckman	Partial	Wednesday, April 12, 2023

Informational:

1	Misc	4-12-23 RH. Approach is formed up and aggregate is placed and compacted. Approach was measured to be 40' which is 4' more than Lee's Summit allows along the curb. Contractor was contacted and will call a back once fixed. Contractor fixed driveway and is approved to pour.
---	------	---

Comments: