

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20222149  
**Address:** 2808 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082  
**Inspected On:** Wednesday, April 12, 2023  
**Inspected By:** Mitchell Schwarz  
**Expiration Date:** 5/12/2023 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Pending	

**Corrective Action Required:**

1	Misc	-sod-splash blocks and sump pump discharge to extend 36" from foundation -bring water meter well to grade. Ensure 14"-18" from meter top to well lid ring -label all non GFCI outlets in unfinished spaces
---	------	--

**Corrective Action Required:**

2	Misc	TCO extension for 30 days for sod
---	------	-----------------------------------