

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20225294  
Address: 5031 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Wednesday, April 12, 2023

Informational:  
1 Misc

Footing approved below:

-Footing under rm 111-114 & 120-122 walls; E/4.5 to E/2 to 2/A

Corrections: provide min 3" rebar clearance; switch F1 and F3 at south location

**Comments:**