

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230960
Address: 1138 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Wednesday, April 12, 2023

Corrective Action Required:

1	Misc	-At fire separation wall: Remove all unused electrical, remove all foam, patch all holes with 5/8 drywall and mud, and seal all gaps with fire caulk -Secure mc within 12" of box at office wall -Install all backing for ADA bars and seat at shower -Midpolint strap all 2" and smaller dwv
---	------	--

****OK TO ROCK ONE SIDE-DON'T COVER INSPECTION ITEMS**

Comments: