## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRRES20216390

Address: 1705 SW 27TH ST, LEES SUMMIT, MO 64082

Inspected On: Wednesday, April 12, 2023

**Inspected By:** Mitchell Schwarz

Expiration Date: 5/12/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection: Outcome: Date:

Occupancy Inspection -

**Codes Residential** 

Mitchell Schwarz

Pending

Corrective Action Required:

1 Misc Pay fee

-sod

-splash blocks and sump pump discharge to extend 36" from

foundation

-check water meter at time of sod. (Ensure meter well flush height

and meter depth in well 14"-18")