

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215472
Address: 2034 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, April 13, 2023

Corrective Action Required:

1 Misc

- Bring water meter well lid to grade (ensure 14"-18" from meter lid to well lid
- guard rail at front porch where more than 30" from ground 36" out
- tamper caps at a/c compressor
- properly support csst Above furnace
- stairs between great room and dining room greater that 3/8 difference in rise

Comments: