

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215184
Address: 2022 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, April 13, 2023

Corrective Action Required:

1 Misc

No further inspections until erosion control is in compliance

- address pending pier inspection
- sod
- splash blocks and sump pump discharge to extend 36" from foundation
- will check water meter at time of sod
- address to be of contrasting color and properly illuminated
- handrail in garage required
- provide spark rings at kitchen outlets as required by code
- secondary locking device at rear slider
- seal all exterior penetrations
- tamper caps at A/c compressor
- spark ring at outlet above fireplace
- shear off set screw at water anti syphon device

Comments: