

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216115
Address: 2114 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, April 13, 2023

Corrective Action Required:

1	Misc	-identify sewer tracer wire -sod splash blocks and sump pump discharge to extend 36" from foundation -obtain issued lawn irrigation permit. -hardware for rear slider -all outlets in master closet/laundry to be GFCI Protected -security screws at rear patio door. 2 per hinge and strike plate
---	------	---

Comments: