

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216303
Address: 2029 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Friday, April 14, 2023

Corrective Action Required:

1 Misc

- Seal all exterior wall penetrations
- Secure A/C whip within 12" of disconnect
- Splash pads not installed
- Pay all fees

Corrective Action Required:

2

Comments: