

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223254
Address: 2758 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Shawn Hoffman	Failed	Monday, April 17, 2023

Corrective Action Required:

1	Misc	- lower water meter pit to grade - lower water meter to 14"-18" below lip of meter pit - lower water valve by fire hydrant to grade
---	------	---

Comments: