

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215796
Address: 2026 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|-----------|------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Not Ready | Monday, April 17, 2023 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | PORTAL FRAME INSPECTION ONLY. -UNCOVER NAILING TO HEADER -SHEATHING BREAKS TO OCCUR IN THE MIDDLE 24" OF PORTAL LEG |
|---|------|---|

Corrective Action Required:

| | | |
|---|------|---|
| 2 | Misc | -maintain gravel filter before any further inspections -no lockbox code for access -provide city stamped plans on site for inspection |
|---|------|---|

Comments: