

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220894

Address: 1025 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1027 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1029 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1023 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, April 17, 2023

Corrective Action Required:

1	Misc	Black Twig
		1027
		-stairs at landing more than 3/8 variance between bottom and top stair
		1029
		-adjust water meter
		Overall notes
		handrail clearance
		Final grade
		Downspout extensions

Comments: