

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220891

Address: 1014 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811016 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811018 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811012 NW BLACK TWIG CIR,
LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, April 17, 2023

Corrective Action Required:

1	Misc	Complete final grade, sod, roof drainage and extensions
---	------	---

1014-Stair risers to be within 3/8" variance

1016-Stair risers to be within 3/8" variances exterior gfcı not working

1018-Stair risers to be within 3/8" variance

Comments: