CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRCOM20220898
Address:	1013 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811015 NW BLACK
	TWIG CIR, LEES SUMMIT, MO 640811017 NW BLACK TWIG CIR, LEES
	SUMMIT, MO 640811019 NW BLACK TWIG CIR, LEES SUMMIT, MO
	640811011 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
Inspected On:	Monday, April 17, 2023
Inspected By:	Robb Popp
Expiration Date:	5/17/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Pending	

Corrective Action Required:

1Misc-Complete final grade, sod, downspout extensions, etc.
-Seal exterior penetrations
-All water meters to be 14"-18" to top of meter pit