

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220586
Address: 908 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|------------|----------|------------------------|
| Electrical Service Inspection | Robb Popp | Failed | Monday, April 17, 2023 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Conduit between meter can and disconnect must be metallic |
|---|------|--|

Comments: