

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221806  
Address: 3208 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ryan Heckman	Passed	Wednesday, April 19, 2023

Corrective Action Required:

1	Misc	4-12-23 RH. Approach is formed up and aggregate is placed and compacted. Approach was measured to be 40' which is 4' more than Lee's Summit allows along the curb. Contractor was contacted and will call a back once fixed.
---	------	--

4-19-23 RH. Approach meets LS and ADA specification.

**Comments:**