

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20230414
Address: 4391 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Kyle Beard	Failed	Wednesday, April 19, 2023

Corrective Action Required:

1	Miscellaneous Correction	-living/rec room needs AFCI installed -electrical panel needs to be better labeled
---	--------------------------	---------------------------------------------------------------------------------------

Comments: