

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20216223  
**Address:** 106 NW AMBERSHAM DR, LEES SUMMIT, MO 64081  
**Inspected On:** Wednesday, April 19, 2023  
**Inspected By:** Robb Popp  
**Expiration Date:** 5/19/2023 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Pending	

**Corrective Action Required:**

1	Misc	-final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -raise water meter well lid to grade (ensure 14"-18" from meter to well lid)
---	------	--