

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231510  
Address: 362 NW PATCH CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Alex Fischer	Partial	Wednesday, April 19, 2023

Corrective Action Required:

1	Misc	-Bonded at 6 points on the pool and 2 points on the hot tub -Ok to pour floor
---	------	--

**Comments:**