

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223031
Address: 362 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|-------------|----------|---------------------------|
| Sidewalk Inspection | Devon Perry | Partial | Wednesday, April 19, 2023 |

Informational:
1 Misc 4-19-23 DP. Sidewalk was formed, aggregate was compacted, cross slopes were in ADA compliance but conditions can change. Approved to pour 4-19-23 NS Sidewalk on East side of the house passed pre pour and ADA Compliant of today for the pre pour.

Comments: