

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214027  
Address: 4721 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Nick Scott	Partial	Wednesday, April 19, 2023

Informational:

1	Misc	6-27-22 AN forms are in place and aggregate is present and compacted (wrong address called in )
---	------	---

Corrective Action Required:

2	Misc	4-5-2023 NS. Site visited and dirt piles and forms are still up. I will come back and check once these are removed. 4-5-23 NS Site Visited and the dirt piles still have not been removed the erosion control has not been fixed and the gutter buddies has not been cleaned out.
---	------	--

Comments: