

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Construction Inspection</b>	John Jackson	Partial	Wednesday, April 19, 2023

Informational:

1 Misc

04/19/23 Wednesday JMJ ( Central Plumbing - Steve )

Contractor installed saddle and meter box for irrigation line. ( Meter will be installed at a later date ).

Meter is connected to the 12"X4" tee with a coupling to 4" valve to a coupling, reduce plate 4'X2"

and 2" poly water running to the irrigation meter box. ( Contractor has already install domestic water saddle, meter, 2" blue poly water, reducers and 4" valve, 12"X4 tee at an earlier date, meter will be installed at a later date for Bldg #1 ).

**Comments:**