

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224220
Address: 2055 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, April 20, 2023

Corrective Action Required:

1	Miscellaneous Correction	- Nail exterior siding to sill plate to code throughout - Address no overlap of top plate exterior corner of MASTER BEDROOM - Solid block cantilever in basement (MECHANICAL ROOM)
---	--------------------------	---

Comments: