

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223170
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	John Jackson	Partial	Thursday, April 20, 2023

Informational:
1 Misc 04/11/23 Tuesday JMJ (Larry Brown excavating, Inc.)
Talked with contractor about installing additional erosion control to contain silt and run-off.

Corrective Action Required:
2 Misc 04/20/23 Thursday JMJ
Site erosion control measure have failed on the Westside of project and entrance.
Muddy water has run-off on private street Northside of Victoria Street. I will again contact contractor to maintain and control soil erosion of site.

Comments: