

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20223259  
Address: 2785 SW 12TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Devon Perry	Passed	Thursday, April 20, 2023

Informational:

1	Misc	4-13-23 DP. DW was formed, aggregate compacted, told to keep 2% cross slope throughout approach. approved to pour
		4-20-23 DP. DW was poured, cross slopes are in compliance, forms have been removed. passed.

**Comments:**