



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20231356, Public Works Right of Way Permit

Address: 811 NE LONE HILL DR, LEES SUMMIT, MO 64064815 NE LONE HILL DR, LEES SUMMIT, MO 64064817 NE LONE HILL DR, LEES SUMMIT, MO 64064813 NE LONE HILL DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Partial	Friday, April 21, 2023

Corrective Action Required

1 Misc

Site Visit- The crew had taken out a panel of sidewalk, the other panel that is existing was under 2%. I checked the forms and the panel that was taken out was set close to 1%. The pre-pour inspection of the approach meets City standards. A post-pour inspection of the approach will take place next week after the approach has been poured to confirm ADA compliance.

Comments: