

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220169
Address: 2006 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, April 24, 2023

Corrective Action Required:

1	Misc	-address pending sidewalk inspection -handrail required in garage -label all non GFCI outlets in unfinished spaces -security screws for back doors -uncover water meter -identify sewer tracer wire
---	------	--

Comments: