

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223368
Address: 2911 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	Adam Nacke	Passed	Wednesday, January 25, 2023

Informational:

1	Misc	1-20-23 DP Crew preformed hydrostatic test on the fire line up by the building and it passed. 1-25-23 DP Crew preformed hydrostatic test on the 6" line running under Independence up to the fire hydrant and it passed. They tested it at 200psi 1-25-23 DP Crew preformed hydrostatic test on the domestic line up by the building and it passed.
---	------	---

Comments: