## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20220523Address:3526 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                | Inspector: | Outcome: | Date:                  |
|--|------------|----------|------------------------|
| Piers/Caissons Inspection -<br>Residential | Kyle Beard | Passed   | Monday, April 24, 2023 |

Corrective Action Required:

1 Miscellaneous Pier holes at the bottom of the patio stairs are only 11 and 15 inches deep. Correction

Comments: