CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210742

Address: 1518 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Alex Fischer Failed Tuesday, April 25, 2023

Residential

Corrective Action Required:

1 Misc -GFCI at front porch loose, doesn't trip

-Label GFCI in garage

-GFCI under sink not working -Secondary lock on sliding doors -self closing hinges at garage door

-lockout needed on water heater breaker

-label non GFCI sump pump

-Spark ring missing at Fireplace outlet -Spark ring missing at kitchen outlets

-Ensure all Arc fault required in breaker panel E3902.16 of the 2018 IRC

-Label non GFCI's in basement -secure whip to water heater

-sump pump discharge 36 inches from foundation -splash blocks to dischargey 36 inches from foundation -secure whip at AC within 12 inches of disconnect box

-obtained issued lawn irrigation permit

Comments: