



2011 NW Topeka Blvd
Topeka, Kansas 66608

785.270.6447

2121 Moodie Road
Lawrence, Kansas 66046

785.856.9600

1100 W Cambridge Circle Drive
Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Wil-Pav
12900 East Kentucky Road
Sugar Creek, MO 64050

ATTN: Dan Ward

WEATHER: Sunny

TEMPERATURE: 70

PROJECT: Wil-Pav On-Call
Living Faith Church
Lee's Summit, MO

DATE: 4/12/23

CFS PERSONNEL: M. Duke

REPORT #: 22-1147-dr-8

DEVIATIONS

DEVIATION

YES ☐

NO ☒

ASPHALT COMPACTION

- Monitored placement of asphalt pavement for surface for parking lot west end. Nuclear density testing performed.
- Asphalt found to be in substantial compliance with the project plans. Test results attached.