

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225142
Address: 374 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, April 27, 2023

Corrective Action Required:

1	Misc	- Anchor bolts to be in middle 1/3 of sill plate - All bathroom vent ductwork to be 4". 3" not allowed - Fire block at top plate in John deer room at short exterior return wall
---	------	--

Comments: