

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215796
Address: 2026 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, April 27, 2023

Informational:

1 Misc

PORTAL FRAME INSPECTION ONLY.
-UNCOVER NAILING TO HEADER
-SHEATHING BREAKS TO OCCUR IN THE MIDDLE 24" OF PORTAL LEG

Corrective Action Required:

3 Misc

- fireblock furr down ends in garage
- missing pfh anchor bolts
- provide support for furr down in garage to ceiling joist above
- fireblock right of garage entry into furr down
- missing nails in hanger above slider
- missing hanger above breakfast area
- missing hanger at front entry
- fire block master bath W wall to ceiling place
- fire block all N 2nd story wall to ceiling space
- fire block master bed NW corner to ceiling space
- fireblock furr down ends in basement
- fireblock vertically to horizontally throughout basement
- fire block S bed 5 wall to floor space

-

Comments: