## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20215276

Address: 3675 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643675 NE AKIN DR, Unit:C, LEES SUMMIT, MO

640643675 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643675 NE AKIN DR, Unit:A, LEES

**SUMMIT, MO 64064** 

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Kyle Beard Failed Friday, April 28, 2023

Commercial

Corrective Action Required:

1 Miscellaneous

Correction -first stair riser from kitchen floor is 8 inches high and not per code (1011.5.2)

-exterior wall penetrations need to be sealed -A/C unit is not installed at time of inspection

-sod and splash pads are not installed

-water meter was not checked at time of inspection because final grading is

not completed

**Comments:**