

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215272

Address: 3679 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643679 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643679 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643679 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Alex Fischer	Failed	Friday, April 28, 2023

Corrective Action Required:

1	Misc	3679 NE Akin
		-check caulk/sealant at all exterior wall penetrations
		Unit A
		-breaker for disposal malfunctioning
		-breaker for island plugs malfunctioning
		Unit B
		-self closing hinges at garage door needs adjusted, doesn't close all the way
		Unit C
		-missing switch plate cover for garbage disposal
		Unit D
		-missing switch plate cover for garbage disposal
		-self closing hinges at garage door needs adjusted, doesn't close all the way

Comments: